



ERRATA
to the 2015 Edition of
Special Design Provisions for Wind & Seismic (SDPWS)
(web version dated 06-15 and printed version dated 07-15)

Page **Revision**

35 In Table 4.3A, revise footnote 6 as follows:

6. Where panels are applied on both faces of a shear wall and nail spacing is less than 6” on center on either side, panel joints shall be offset to fall on different framing members ~~as shown below~~. Alternatively, the width of the nailed face of framing members shall be 3” nominal or greater at adjoining panel edges and nails at all panel edges shall be staggered.